

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20170499, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Wednesday, July 26, 2017

Comments: RELEASE ELECTRICAL SERVICE. A/E HAS DIRECTED REINFORCEMENT OF BAR JOISTS SUPPORTING TRANSFORMER. PERMANENT LABELING TO BE AFFIXED TO SERVICE EQUIPMENT BEFORE OCCUPANCY INSPECTION.