PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171199, Building Permit - Commercial Address: 308 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Above Ceiling John Borns Not Ready Wednesday, July 26, 2017

Inspection

Corrective Action Required

1 Misc CLARIFICATION REQUIRED FROM FIRE DEPT RE SPRINKLER

HEADS. DO NOT HANG ANY CEILING DRYWALL. FD CARD

PROVIDED HEREWITH.

In-wall Inspection John Borns Partial Wednesday, July 26, 2017

Partial Correction

1 Misc EXTEND STAND-OFF ON ELECT RECEPT UNDER 312 SUB-PANEL.

THEN OK TO HAND DRYWALL EXCEPT AT CROSSWALL AT EAST

ENTRANCE WHERE ELECTRICAL WIRING IS INCOMPLETE.

Comments: