

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161942, Building Permit - Commercial
Address: 819 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Not Ready	Wednesday, July 26, 2017

Corrective Action Required

1	Misc	FLUSH NAIL EXTERIOR AND INTERIOR SHEATHING PER APPROVED DRAWINGS. CHECK DOOR HEADER BEARING ON JACK STUDS; SHIM ALL GAPS. COMPLETE/CORRECT SILL PLATE ANCHORAGE; SEE PAINT-MARKED LOCATIONS
---	------	--

Corrective Action Required

2	Misc	ROOF SHEATHING NAILS ARE OVER-DRIVEN; SOME LINES MISSING
---	------	---

Comments: