

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161943, Building Permit - Commercial
Address: 819 NW DONOVAN RD, Unit:G2, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|-----------|--------------------------|
| Rough Framing Inspection - Commercial | John Borns | Not Ready | Wednesday, July 26, 2017 |

Corrective Action Required

| | | |
|---|------|--|
| 1 | Misc | FLUSH NAIL EXTERIOR AND INTERIOR SHEATHING PER APPROVED DRAWINGS. CHECK DOOR HEADER BEARING ON JACK STUDS; SHIM ALL GAPS. COMPLETE/CORRECT SILL PLATE ANCHORAGE; SEE PAINT-MARKED LOCATIONS |
|---|------|--|

Corrective Action Required

| | | |
|---|------|--|
| 2 | Misc | ROOF SHEATHING NAILS ARE OVERDRIVEN. SOME LINES MISSIONG. |
|---|------|--|

Comments: