

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, July 27, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY RATED ASSEMBLIES AT STAIRWELLS:

FRAMING + SHAFT LINER BOARD -- WELL FACE + UNIT SIDE AT:
102; 202; 203; 213; 302; 303; 313; 314;

WEST STAIRWELL:
FRAMING + SHAFT LINER BOARD INCLUDING CLIPS AND
FIRE-BLOCKING -- WELL FACE + OPPOSITE FACE AT 3RD FLOOR
(303); AT 4TH FLOOR (402) WELL FACE GWB COMPLETE TO ROOF;
OPPOSITE FACE AT 2ND FLR (203) OK FOR 5/8" TYPE X; [5/8" TYPE
X OK TO TAPE, MUD AND FIRE-STOP AT 402 UP TO ROOF;
OPPOSITE FACE AT 403 OK TO HANG 5/8" TYPE X;

SE STAIRWELL: 5/8" TYPE X GWB AT STAIRWELL FACE WEST
WALL ABOVE LID AT 4TH FLR;

5/8" TYPE X GWB AT BACK FACE AT: WALLS ABOVE 4TH FLR
CEILING AT ATTIC;

Partial Correction
2 Misc

DUCT CHASE AT 303 SW CORNER:
TWO LAYERS 5/8" TYOE X GWB AT CORRIDOR WALL -- OK TO
TAPE & MUD, THEN TO INSTALL DUCT, THEN TO INSTALL PART OF
SHAFT LINER ENCLOSURE, LEAVING OPENING FOR INSPECTION
BEFORE COMPLETELY CLOSING CHASE.

DUCT CHASE AT 306 SW CORNER:
SIMILAR TO 303 ABOVE.

Partial Correction
3 Misc

**[OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB AT WALLS
AND CEILINGS IN 203 & 303**

**Electrical Service
Inspection -
Commercial**

John Borns

Passed

Thursday, July 27, 2017

Comments: RELEASE PERMANENT ELECTRICAL SERVICE.