

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20171199, Building Permit - Commercial  
Address: 308 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Not Ready	Thursday, July 27, 2017

Corrective Action Required

1	Misc	GENERAL CONTRACTOR OR SPRINKLER CONTRACTOR UTILIZE FIRE DEPARTMENT BUSINESS CARD LEFT 7/26 TO CONTACT FIRE DEPT RE SPRINKLER HEADS IN AREAS TO RECEIVE CEILING. DO NOT HANG ANY CEILING DRYWALL BEFORE APPROVAL.
---	------	---

**Comments:**