

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161761, Building Permit - Commercial  
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Thursday, July 27, 2017
Partial Correction 1 Misc		SHEAR WALLS AT STAIRWELLS: SOUTH STAIR: 1ST FLOOR; NORTH STAIR: 1ST FLOOR;	
Partial Correction 2 Misc		<b>OK TO COVER WHEN READY INTERIOR VERTICAL STRAPS AT GARAGE PORTALS</b>	

**Comments:**