

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161756, Building Permit - Commercial
Address: 795 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Not Ready	Thursday, July 27, 2017

Partial Correction

1	Misc	OK TO PRE-ROCK WHEN READY AT SHOWERS AT: 4TH FLOOR; 3RD FLOOR; 2ND FLR; 1ST FLR;
---	------	---

Corrective Action Required

2	Misc	AT 4TH FLOOR PENTHOUSE EXTERIOR WALLS NO INSTALLATION CLEARANCE EXISTS BETWEEN BOTTOM OF WINDOWS AND TRIPLE BOTTOM PLATES. PLATES MAY NOT BE SEVERED FOR INSTALLATION OF BOXES AND CABLE. IF A/E SO DIRECTS LISTED FLOOR BOXES AND RECEPTACLES WILL BE APPROVABLE.
---	------	---

Comments: