

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160836, Building Permit - Commercial
Address: 2641 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Failed	Friday, July 28, 2017

Corrective Action Required

1	Misc	-OBTAIN APPROVAL FROM OTHER DEVELOPMENT DIVISIONS: PLANNING, FIRE, WATER, AND ENGINEERING. OUTSTANDING ISSUES UNDER SEPARATE COVER. -STRIPE PARKING LOT FOR TEMP. -SUBMIT CODE MODIFICATION FOR WORKING CLEARANCE IN FRONT OF TRANSFORMER TRANSFER SWITCH. -ALL EXTERIOR RECEPTACLES REQUIRED TO BE SUITABLE FOR WET LOCATIONS. -INSTALL PERMANANT ADDRESS VISABLE FROM PUBLIC WAY. (TEMP ADDRESS INSTALLED) -COMPLETE ALL BATHROOMS, INSTALL KNEE GUARDS FOR SINKS
---	------	---

Comments: