

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20171326, Building Permit - Residential
Address: 1828 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mark Harding	Passed	Monday, July 31, 2017
All Rough Inspection - Residential	Mark Harding	Failed	Monday, July 31, 2017

Corrective Action Required

1	Misc	<ul style="list-style-type: none">-missing lvl's basement, 1st floor, attic for roof support. revise plans or install per plans. check all roof support and location of lvls at re-inspection.- fur out fireplace flue, flue clearance to pvc and wood.- connect gas line at fireplace, protect wardflex at fireplace.-firestop kitchen hood dead space.- firestop garage wall fur down.-support bottom of stairs stringers to 2nd floor.-nail dbl joist 16" oc.c-snow blocking mstr bedroom bathroom.support ridge over 3rd car.
---	------	---

Comments: