

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20160277  
**Address:** 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086  
**Inspected On:** Monday, July 31, 2017  
**Inspected By:** John Borns  
**Expiration Date:** 10/5/2017 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Monday, July 31, 2017

Corrective Action Required:

1 Misc ROOFTOP:  
- COMPLETE LIGHTNING PROTECTION SYSTEM  
- SECURE A/C WHIP TO WALL  
- FINAL CLEANUP

Corrective Action Required:

2 Misc COMPLETE ALL REQUIRED ITEMS IN ELECTRICAL ROOMS AND  
REQUEST RE-INSPECTION:  
- PERMANENT LABEL PANEL FRONTS  
- ENSURE ALL C.B. POSITIONS NUMBERED  
- PLACE PERMANENT PANEL SCHEDULES

Corrective Action Required:

3 Misc  
- RESOLVE FIRE DEPARTMENT ISSUES  
- RESOLVE PUBLIC WORKS ISSUES  
- RESOLVE PLANNING ISSUES

Partial Correction:

4 Misc PROVIDE COPY OF STATE ELEVATOR INSPECTION CERTIFICATE.

Corrective Action Required:

5 Misc ALL AREAS OF BUILDING INCLUDING AREAS 1-B AND 1-D OK FOR OCCUPANCY PENDING COMPLETION AND APPROVAL OF OUTSTANDING ISSUES.