

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161939, Building Permit - Commercial
Address: 825 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Monday, July 31, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY EXTERIOR WALL SHEATHING,
EXTERIOR PORTAL STRAPS, INTERIOR PORTAL STRAPS, AND ROOF
SHEATHING

Comments: