

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161750, Building Permit - Commercial
Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Failed	Monday, July 31, 2017

Partial Correction

1 Misc

OK TO COVER AT PORTALS AT ATTACHED GARAGES: INSIDE REINF STRAPS;

Partial Correction

2 Misc

OK TO COVER WHEN READY SHEAR WALLS AT STAIRWELLS:
SOUTH STAIRWELL: LEVEL 1;
NORTH STAIRWELL: LEVEL 1;

Corrective Action Required

3 Misc

PRELIMINARY FRAMING INSPECTION AT BASEMENT: CORRECT ALL ISSUES MARKED AT LOCATIONS; THEN REQUEST RE-INSPECTION

Comments: