

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

August 01, 2017

MID-AMERICA CONTRACTORS INC
1400 IRON
KANSAS CITY, MO 64116

Permit No: PRCOM20172493
Project Title: LOCKE KARATE STUDIO
Project Address: 431 SW WARD RD, LEES SUMMIT, MO 64081
Parcel Number: 61420042900000000
Location: WESTSIDE PLAZA LOTS 1A, 1B, 2A & 2B & TRS A & B---LOT 1A
Type of Work: CHANGE OF TENANT
Occupancy Group:
Description: TENANT FINISH FOR KARATE STUDIO

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors	Reviewed By: Joe Frogge	Approved
Building Plan Review	Reviewed By: Joe Frogge	Approved
Fire Plan Review	Reviewed By: Joe Dir	Approved with Conditions

1. Door operation

ACTION REQUIRED no keyed locks on the egress side of an exit

[B] 1008.1.9 Door operations.

Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

2. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED (verified at inspection)

Post the address on the exterior of the front and back doors. Address shall be readable from the roadway.

☒ Approved to issue per the listed conditions.
☐ Do not issue per the listed conditions.
☐ Approved to construct foundation only per the listed conditions.

_____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

_____	_____
Signature of Applicant	Date

_____	_____
Print Applicant Name	CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.