

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Not Ready	Tuesday, August 01, 2017

Gas Piping Inspection - Commercial	John Borns	Partial	Tuesday, August 01, 2017
---	------------	---------	--------------------------

Partial Correction
1 Misc

NATURAL GAS FEEDER PIPE TRENCHED FROM MOORE ST / HOPE LN SW TO BUILDING ENTRY AT SOUTH ELEVATION. TRENCH DEPTH ~ 28"; TRACER WIRE IN PLACE.

8/1/17 PRESURE TEST HELD STEADY AT 100 PSI FOR 60 MINUTES.

Comments: