

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161771, Building Permit - Commercial
Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, August 01, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY AT STAIRWELLS:
SOUTH STAIRWELL:
AT BASEMENT: 1ST LAYER 5/8" TYPE X GWB INCLUDING PRE-ROCK;

Partial Correction
2 Misc

OK TO COVER WHEN READY AT ELEVATOR:
AT BASEMENT: 1ST LAYER 5/8" TYPE X GWB INCLUDING PRE-ROCK;

Comments: