

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161767, Building Permit - Commercial  
Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Tuesday, August 01, 2017

Partial Correction  
1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT:  
**SOUTH STAIRWELL:**  
**1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK;**

**NORTH STAIRWELL:**  
**1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK;**

Partial Correction  
2 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT ELEVATOR  
**1ST FLOOR: 1ST LAYER PRE-ROCK;**

**Comments:**