

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Failed	Wednesday, August 02, 2017

Partial Correction

1 Misc

RATED CEILING ASSY OK BELOW:

-ZONE A-OK

-ZONE C-OK

-ZONE B: ALL AREAS EXCEPT HEARTH&GATHERING

SMOKE BARRIERS WALL:

-ZONE A&C: ALL SB WALL FROM CEILING TO ROOF DECK-OK

CORRIDOR SMOKE PARTITION WALL:

-ZONE C-OK

Corrective Action Required

2 Misc

KITCHEN AREA NOT READY, STILL SCREWING 12" O.C. AND NEED TO FIRECAULK PENETRATIONS.

Comments: