

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161756, Building Permit - Commercial
Address: 795 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Wednesday, August 02, 2017

Corrective Action Required

2 Misc

4TH FLOOR:

- CLOSE HOLES / GAPS IN DRAFT STOPS
- FIRE-BLOCK TOPS OF CHASES & DEAD SPACES
- FIRE-BLOCK HOLES IN R.A. WALL PLENUMS
- PUTTY PAD ELECTRICAL BOXES PER IBC 712.3.2 INCLUDING BOXES HIGH ON WALLS
- FIRE-CAULK PEX PENETRATIONS OF RATED WALLS IN BATHROOMS

Partial Correction

3 Misc

OK TO COVER AT STAIR TOWERS: CEILING AT 4TH FLOOR (TOP) OF SOUTH AND NORTH TOWERS;

Comments: