

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171689, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Not Ready	Wednesday, August 02, 2017

Corrective Action Required

1	Misc	PARAPET WALL COVERED ROOF FACE AND TOP PRIOR TO INSPECTION. LOWER WALL LATERAL BRACING NOT PER DRAWING.
---	------	---

Comments: