

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170306, Building Permit - Residential

Address: 2232 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822234 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822236 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822230 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mark Harding	Passed	Wednesday, August 02, 2017

Corrective Action Required

1	Misc	Grounding conductor from UFA enters meter bank, but is not connected to anything.
---	------	---

All Rough Inspection - Residential	Mark Harding	Failed	Wednesday, August 02, 2017
---	--------------	--------	----------------------------

Corrective Action Required

1	Misc	ok to insulate 2236 support i beam bsmt full width 2234 connect 2nd floor shower all units firestop vertical to horizontal heat chase 1st floor left to right in joist space.
---	------	---

Rated Assembly Inspection	Mark Harding	Passed	Wednesday, August 02, 2017
----------------------------------	--------------	--------	----------------------------

Comments: