

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20160836  
**Address:** 2641 NE MCBAINE DR, LEES SUMMIT, MO 64064  
**Inspected On:** Wednesday, August 02, 2017  
**Inspected By:** Mike Copeland  
**Expiration Date:** 12/31/1899 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Mike Copeland	Temporary C of O	Wednesday, August 02, 2017

**Corrective Action Required:**

- |   |      |  |
|---|------|--|
| 1 | Misc | -OBTAIN APPROVAL FROM OTHER DEVELOPMENT DIVISIONS:<br>PLANNING, FIRE, WATER, AND ENGINEERING. OUTSTANDING ISSUES<br>UNDER SEPARATE COVER.<br><br>-SUBMIT CODE MODIFICATION FOR WORKING CLEARANCE IN<br>FRONT OF TRANSFORMER TRANSFER SWITCH.<br>-ALL EXTERIOR RECEPTACLES REQUIRED TO BE SUITABLE FOR WET<br>LOCATIONS.<br>-INSTALL PERMANANT ADDRESS VISABLE FROM PUBLIC WAY.<br>(TEMP ADDRESS INSTALLED)<br>-COMPLETE ALL BATHROOMS, INSTALL KNEE GUARDS FOR SINKS |
|---|------|--|