

Temporary Certificate of Occupancy

Permit #: PRCOM20160836
Address: 2641 NE MCBAINE DR, LEES SUMMIT, MO 64064
Inspected On: Wednesday, August 02, 2017
Inspected By: Mike CopelandMike Copeland
Expiration Date: 8/11/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Temporary C of O	Wednesday, August 02, 2017

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -OBTAIN APPROVAL FROM OTHER DEVELOPMENT DIVISIONS:
PLANNING, FIRE, WATER, AND ENGINEERING. OUTSTANDING ISSUES
UNDER SEPARATE COVER.

-SUBMIT CODE MODIFICATION FOR WORKING CLEARANCE IN
FRONT OF TRANSFORMER TRANSFER SWITCH.
-ALL EXTERIOR RECEPTACLES REQUIRED TO BE SUITABLE FOR WET
LOCATIONS.
-INSTALL PERMANANT ADDRESS VISABLE FROM PUBLIC WAY.
(TEMP ADDRESS INSTALLED)
-COMPLETE ALL BATHROOMS, INSTALL KNEE GUARDS FOR SINKS |
|---|------|--|

Occupancy Inspection - Codes Commercial	Mike Copeland	Temporary C of O	Wednesday, August 02, 2017
--	---------------	------------------	-------------------------------

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">-OBTAIN APPROVAL FROM OTHER DEVELOPMENT DIVISIONS: PLANNING, FIRE, WATER, AND ENGINEERING. OUTSTANDING ISSUES UNDER SEPARATE COVER.
-SUBMIT CODE MODIFICATION FOR WORKING CLEARANCE IN FRONT OF TRANSFORMER TRANSFER SWITCH.-ALL EXTERIOR RECEPTACLES REQUIRED TO BE SUITABLE FOR WET LOCATIONS.-INSTALL PERMANANT ADDRESS VISABLE FROM PUBLIC WAY. (TEMP ADDRESS INSTALLED)-COMPLETE ALL BATHROOMS, INSTALL KNEE GUARDS FOR SINKS |
|---|------|--|