

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161938, Building Permit - Commercial
Address: 813 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, August 03, 2017

Corrective Action Required

1	Misc	INTERIOR - CHECK DOOR HEADER BEARING ON JACK STUDS; SHIM ALL GAPS. - COMPLETE/CORRECT SILL PLATE ANCHORAGE; SEE PAINT-MARKED LOCATIONS. COMPLETE NAILING OF INTERIOR SHEATHING; SEE - PAINT MARKED LOCATIONS.
Partial Correction		
2	Misc	EXTERIOR WALL AND ROOF SHEATHING OK TO COVER WHEN READY.
Partial Correction		
3	Misc	INTERIOR PORTAL STRAPS FOUND INSTALLED AT NEXT-TO-END BAYS. OK TO COVER WHEN READY.

Comments: