

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161937, Building Permit - Commercial
Address: 801 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, August 03, 2017

Partial Correction

1 Misc

INTERIOR:

- CHECK DOOR HEADER BEARING ON JACK STUDS; SHIM ALL GAPS.
- COMPLETE/CORRECT SILL PLATE ANCHORAGE; SEE PAINT-MARKED LOCATIONS.
COMPLETE NAILING OF INTERIOR SHEATHING; SEE - PAINT MARKED LOCATIONS.

Partial Correction

2 Misc

EXTERIOR WALL AND ROOF SHEATHING OK TO COVER WHEN READY.

Partial Correction

3 Misc

INTERIOR PORTAL STRAPS FOUND INSTALLED AT NEXT-TO-END BAYS. OK TO COVER WHEN READY.

Comments: