

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Thursday, August 03, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING +
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES:
**4TH FLOOR: CORRIDOR 401/416 EXCEPT ELEVATOR LOBBY
AFTER ALL TENSION STUDS ARE SCREWED BOTH FLANGES; 418;**

Comments: