

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20171326, Building Permit - Residential  
Address: 1828 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Dale Carter	Failed	Thursday, August 03, 2017

### Corrective Action Required

1	Misc	-missing lvl's basement, 1st floor, attic for roof support. revise plans or install per plans. check all roof support and location of lvls at re-inspection.
		- connect gas line at fireplace, protect wardflex at fireplace.
		*OK to insulate / rock, but don't cover structure that still needs to be inspected upon receipt of revised plans.

### Comments: