



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20171689 Date: August 03, 2017
Project Title: SAINT LUKES EAST - OR ADDITION #2 Applicant:
Location: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086 JAYHAWK FIRE SPRINKLER CO INC
12030 S. Hedge Lane Terrace
Olathe, Kansas 66061
Type of Work: Primary: (913) 422-3770
Occupancy Group: I-2
Description: BUILDING ADDITION FOR SURGERY DEPARTMENT INCLUDING INTERIOR ALTERATIONS TO ADJACENT SPACES
foundation permit: PRCOM20170703
Construction Type: Type IA
Map Page: 175X

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Hydrostatic pressure test required for the sprinkler system addition. to schedule the testing contact the fire department at 816-969-1300

3. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED: (verified at inspection)

The existing fire sprinkler system shall be current with all required maintenance and servicing. A current service tag shall be posted on the riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.