

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161769, Building Permit - Commercial
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Friday, August 04, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY **SHEAR WALLS AT STAIRWELLS:
1ST FLOOR: EAST AND WEST STAIRWELLS;**

Partial Correction
2 Misc

OK TO COVER WHEN READY PORTALS AT ATTACHED GARAGES:
INTERIOR PORTAL REINFORCING STRAPS;

Comments: