

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161769, Building Permit - Commercial  
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Monday, August 07, 2017

Partial Correction  
1        Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT STAIRWELLS  
AND ELEVATOR SHAFT:

EAST STAIRWELL:  
1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK;

WEST STAIRWELL:  
1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK;

ELEVATOR SHAFT:  
1ST FLOOR: 1ST LAYER PRE-ROCK;

**Comments:**