

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

August 07, 2017

SCHARHAG ARCHITECTS
310 ARMOR RD, #22
NORTH KANSAS CITY, MO 64116

Permit No: PRCOM20172659
Project Title: TOTAL BODY FITNESS
Project Address: 3680 NE AKIN DR, Unit:128, LEES SUMMIT, MO 64064
Parcel Number: 43810020700000000
Location: CHAPEL RIDGE BUSINESS PARK, LOTS 10-18 & TRACTS H THRU K---LOT 17
Type of Work: CHANGE OF TENANT
Occupancy Group: ASSEMBLY FOR INDOOR SPORTING INCL ARENAS, RINKS, COURTS, SWIMMING POOLS
Description: TENANT EXPANSION INTO ADJACENT SPACE

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

2. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

CODES ADMINISTRATION

2. The project cost, which is used to establish the permit fee, has not been provided.

Action required: Comment is for informational purposes.

3. 2012 IMC 403.2 Outdoor air required. The minimum outdoor airflow rate shall be determined in accordance with Section 403.3. Ventilation supply systems shall be designed to deliver the required rate of outdoor airflow to the breathing zone within each occupiable space.

Action required: Revise drawings to show outside air calculations as well as method of delivery.

Fire Plan Review**Reviewed By: Joe Dir****Approved with Conditions**

1. 2012 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

ACTION REQUIRED: (verified at inspection)

Post the occupant load (160) around the front entrance

2. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

ACTION REQUIRED: (information purposes)

Have the fire alarm system contractor provide shop drawings for any modification to be done to the fire alarm system.

3. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

post the numeric address on all doors leading into the suite. Address shall be readable from the roadway.

4. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED: (information purposes)

Have the fire sprinkler system contractor provide shop drawings of any modifications to be done to the fire sprinkler system.

6. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED: (verified at inspection)

the existing fire sprinkler system shall be current with all maintenance and service. A current service tag shall be posted on the riser.

CODES ADMINISTRATION

7. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED: (verified at inspection)

Provide one 2A-10BC fire extinguisher for every 3,000 sq ft of the business. Extinguishers to be mounted close to an exit.

8. Door operations

ACTION REQUIRED: No keyed locks on the egress side of an exit

[B] 1008.1.9 Door operations.

Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

[B] 1008.1.10 Panic and fire exit hardware.

Doors serving a Group H occupancy and doors serving rooms or spaces with an occupant load of 50 or more in a Group A or E occupancy shall not be provided with a latch or lock unless it is panic hardware or fire exit hardware.

Exception: A main exit of a Group A occupancy in compliance with Section 1008.1.9.3, Item 2.

9. Egress.

ACTION REQUIRED: (verified at inspection)

All exit signs and emergency lighting shall illuminate on both AC current and DC battery power.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.