

Temporary Certificate of Occupancy

Permit #: PRRES20170161
Address: 1695 NE PARKWOOD DR, LEES SUMMIT, MO 64064
Inspected On: Monday, August 07, 2017
Inspected By: Khanh Nguyen
Expiration Date: 9/7/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Monday, August 07, 2017

- HAVE THE LAWN IRRIGATION SUB SEND BACKFLOW TEST REPORT TO WATER DEPARTMENT
- BRING THE WATER METER TO FINAL GRADE
- FINAL GRADE, SOD, SPLASHBLOCKS
- SEAL EXTERIOR WALL PENETRATIONS
- PROVIDE STAIR ILLUMINATION PER CODE
- INSTALL KITCHEN HOOD