

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170437, Building Permit - Residential

Address: 2202 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822204 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822206 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822200 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Monday, August 07, 2017

Corrective Action Required

1	Misc	- Garage wall hose bib needs sealed all units- -label all bedrooms, smokes(mstr bed,bed 2, front bed) -2204 afci does not work sod, erosion control etc.
---	------	--

Comments: