

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20162552, Public Works Infrastructure Permit - Commercial

SUMMIT SQUARE APARTMENTS

Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Erosion Sediment Control (ESC) Inspection	Steve Robbins	Partial	Monday, August 07, 2017

Informational

- 1 This job site has mulch berms all around the outside of the site. After the rain on Saturday the berm is still in place, there are 2 areas that got washed out, the location is on the east side of the property behind the garages. I will talk with Jonathan Meyers today. Steve Robbins 08/07/2017 8:44 AM

Comments: