

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Khanh Nguyen	Failed	Monday, August 07, 2017

Corrective Action Required

1	Misc	-PROVIDE IRREVERSIBLE SPLICE FOR THE GROUNDING ELECTRODE CONDUCTOR
---	------	---

Rated Assembly Inspection	Khanh Nguyen	Partial	Monday, August 07, 2017
--------------------------------------	--------------	---------	-------------------------

Partial Correction

1	Misc	<p>RATED CEILING ASSY OK BELOW: -ZONE A-OK -ZONE C-OK -ZONE B: ALL AREAS EXCEPT HEARTH&GATHERING</p> <p>SMOKE BARRIERS WALL: -ZONE A&C: ALL SB WALL FROM CEILING TO ROOF DECK-OK</p> <p>CORRIDOR SMOKE PARTITION WALL: -ZONE A&C-OK</p> <p>COMMON AREA WALLS-OK</p>
---	------	---

Comments: