

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170985, Building Permit - Commercial
Address: 1706 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Not Ready	Monday, August 07, 2017

Corrective Action Required

1	Misc	RESTROOM WALL SURFACES MUST BE NON-ABSORBENT (EPOXY OR APPROVED EQUAL).
---	------	---

Corrective Action Required

2	Misc	RESTROOM SIGNS MUST HAVE WHEELCHAIR SYMBOL TO INDICATE "ACCESSIBLE"
---	------	---

Corrective Action Required

3	Misc	PHASE 1 SPACE OK FOR USE WITH CORRECTIONS OF ABOVE TO BE COMPLETED AND APPROVED NO LATER THAN 8/14/17.
---	------	---

Occupancy Inspection - Fire	Michael Weissenbach	Partial	Monday, August 07, 2017
--	------------------------	---------	-------------------------

Comments: