

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Erosion Sediment Control (ESC) Inspection	Brice Lawson	Failed	Monday, August 07, 2017

Corrective Action Required

1 Brice Lawson 08/07/2017 3:15 PM

Repair the west construction entrance as part of it has washed out.

Add larger rock to the construction entrances as shown on the construction entrance detail.

Remove debris that has been tracked onto County Line Rd.

Comments: