

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161758, Building Permit - Commercial
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Tuesday, August 08, 2017

Partial Correction
1 Misc

NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP AT OUTDOOR LOUNGE

Gas Piping Inspection - Commercial	John Borns	Partial	Tuesday, August 08, 2017
---	------------	---------	--------------------------

Partial Correction
1 Misc

1" TRACPIPE COUNTERSTRIKE TUBING TRENCHED FROM METER TO FIREPLACE PREVIOUSLY COVERED; FROM FIREPLACE TO GRILLES AREA EXPOSED FOR INSPECTION;

Comments: