



**LEE'S SUMMIT**  
**MISSOURI**



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20170916	Date:	August 09, 2017
Project Title:	Lee's Summit Medical Center Tower	Applicant:	
Expansion			
Location:	2100 SE BLUE PKWY, LEES SUMMIT, MO 64063	AMERICAN FIRE SPRINKLER CORPORATION	
		PO BOX 958	
		MISSION, KS 66201	
Type of Work:			
Occupancy Group:	I-2	Primary:	(913) 722-6900
Description:	ADDITION OF 3RD FLOOR TO EXISTING HOSPITAL - INCLUDES NEW GRADE LEVEL CHILLER ROOM AND ALTERATIONS ON 2ND FLOOR		
Construction Type:	Type IB		
Map Page:	196K		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Field (hydrostatic pressure) testing will be required for the third floor addition prior to the final occupancy inspection. Contact the fire department for testing, 816-969-1300

2. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED:(information purposes)

the existing risers shall be current with all required maintenance and service. current tags shall be posted on the risers.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**