

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161177, Building Permit - Commercial  
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, August 09, 2017

Partial Correction  
1 Misc

OK TO COVER WHEN READY RATED ASSEMBLIES AT STAIRWELLS:  
NORTHWEST STAIRWELL & SOUTHEAST STAIRWELL: 5/8" TYPE X  
GWB AT STAIRWELL FACE OK TO TAPE, MUD, AND FIRE-STOP; 1ST  
FLOOR LEVEL AT NW STAIR

Partial Correction  
2 Misc

DUCT CHASE AT 303/403 SW CORNER:  
TWO LAYERS 5/8" TYPE X GWB AT CORRIDOR WALL -- OK TO TAPE  
& MUD, THEN TO INSTALL DUCT, THEN TO INSTALL PART OF  
SHAFT LINER ENCLOSURE; **DUCT & FRAMING OK TO COMPLETE  
SHAFT LINER ENCLOSURE, THEN APPLY ONE LAYER 5/8" TYPE X  
GWB;**

DUCT CHASE AT 306/406 SW CORNER:  
TWO LAYERS 5/8" TYPE X GWB AT CORRIDOR WALL -- OK TO TAPE  
& MUD, THEN TO INSTALL DUCT, THEN TO INSTALL PART OF  
SHAFT LINER ENCLOSURE; **DUCT & FRAMING OK TO COMPLETE  
SHAFT LINER ENCLOSURE, THEN APPLY ONE LAYER 5/8" TYPE X  
GWB;**

Partial Correction  
3 Misc

OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB AT WALLS  
AND CEILING IN: 203; 303; [103; 403; STAIRWELL 202/302/402  
AND 213/313/413;

**Comments:**

