

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161758, Building Permit - Commercial
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, August 10, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY 2" PVC CONDUIT TRENCHED FROM TRANSFORMER LOCATION AT SOUTH END OF BLDG #7 TO NE CORNER OF TRASH COMPACTOR ENCLOSURE

Partial Correction

2 Misc

OK TO COVER WHEN READY PVC CONDUIT LAID ON SUB-BASE TO FIREPLACE AND GRILLE AREA AT OUTDOOR LOUNGE

Partial Correction

3 Misc

OK TO COVER WHEN READY 1/2" PVC CONDUIT FOR LIGHT BOLLARDS AT FRONT OF CLUBHOUSE -- FROM NORTH TO BUILDING ENTRY

Comments: