

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151744, Building Permit - Commercial
Address: 2640 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, August 11, 2017

Corrective Action Required

1	Misc	-SUBMIT SPECIAL INSPECTION APPROVAL -APPROVAL FROM THE FOLLOWING DEPTS REQUIRED: FIRE, PUBLIC WORKS, PLANNING, WATER -INSTALL LADDER TO ROOFTOP -PAINT RUSTED ROOFTOP GAS PIPING
---	------	--

Comments: