

Temporary Certificate of Occupancy

Permit #: PRCOM20171522
Address: 2640 NE MCBAINE DR, LEES SUMMIT, MO 64064
Inspected On: Friday, August 11, 2017
Inspected By: Khanh Nguyen Michael Weissenbach
Expiration Date: 9/11/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Passed	Friday, August 11, 2017
Occupancy Inspection - Fire	Michael Weissenbach	Passed	Friday, August 11, 2017
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, August 11, 2017

Corrective Action Required:

1	Misc	-STORAGE RACK SYSTEM NOT INSTALLED AT THIS TIME -COMPLETE CUBICLE INSTALLATION. MAKE SURE EGRESS PATHWAY IS COMPLIANT -SECURE FMC WITHIN 12" OF PANEL. MOP SINK RM -INSTALL MAX 25 AMP BREAKER FOR ROOFTOP AC AT NE CORNER -SPRINKLER HEAD MISSING IN IT ROOM
---	------	---

-THE URINAL PARTITION IS NOT COMPLIANT. MIN. 5 FT HEIGHT
AND THE BOTTOM NO MORE THAN 12" ABOVE FLOOR