

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20171304, Building Permit - Residential
Address: 4725 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Khanh Nguyen	Failed	Friday, August 11, 2017

Corrective Action Required	
1 Misc	NO PRESSURE

All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, August 11, 2017
---	--------------	--------	-------------------------

Corrective Action Required	
1 Misc	-FIREBLOCK THE WALL SPACE FROM SOFFITS OUTSIDE BASEMENT BATH AND FROM SOFFIT INSIDE BEDROOM

Comments: