

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161769, Building Permit - Commercial
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, August 11, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT STAIRWELLS
AND ELEVATOR SHAFT:

EAST STAIRWELL:
1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; **[2ND LAYER
PRE-ROCK ONLY;**
2ND FLOOR: [1ST LAYER INCLUDING PRE-ROCK;

WEST STAIRWELL:
1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; **[2ND LAYER
PRE-ROCK ONLY;**
2ND FLOOR: [1ST LAYER INCLUDING PRE-ROCK;

ELEVATOR SHAFT:
1ST FLOOR: 1ST LAYER PRE-ROCK; **[2ND LAYER PRE-ROCK**

Comments: