

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20170595, Building Permit - Residential  
Address: 1341 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Partial	Monday, August 14, 2017

Corrective Action Required

1	Misc	-PROVIDE MIN. 1.5" OF BEARING UNDER NOTCHED JOIST ABOVE THE SEWER CLEANOUT **ADD A PIECE OF GREEN SILL PLATE UNDER THE JOIST  ***OK TO ROCK
---	------	--

**Comments:**