

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161769, Building Permit - Commercial
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, August 14, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT STAIRWELLS
AND ELEVATOR SHAFT:

EAST STAIRWELL:

1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER
PRE-ROCK ONLY; **[2ND LAYER WALLS ONLY;**
2ND FLOOR: 1ST LAYER INCLUDING PRE-ROCK; **[2ND LAYER
PRE-ROCK;**

WEST STAIRWELL:

1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER
PRE-ROCK ONLY; **[2ND LAYER WALLS ONLY;**
2ND FLOOR: 1ST LAYER INCLUDING PRE-ROCK; **[2ND LAYER
PRE-ROCK;**

ELEVATOR SHAFT:

1ST FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK

Comments: