

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170201, Building Permit - Residential

Address: 2233 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822235 SW BURNINGWOOD LN, LEES
SUMMIT, MO 640822237 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822231 SW
BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once
all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Monday, August 14, 2017

Corrective Action Required

1	Misc	LABEL ALL BREAKERS- SMOKES AND BEDROOMS, 1,2,3 ETC. SOD EROSION CONTROL STREET CURB REPAIR NEEDED ASAP
---	------	--

Comments: