

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170431, Building Permit - Residential

Address: 2222 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822224 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822226 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822220 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|-------------------------|
| Electrical Service Inspection - Residential | Mark Harding | Passed | Monday, August 14, 2017 |
| Rated Assembly Inspection | Mark Harding | Passed | Monday, August 14, 2017 |
| All Rough Inspection - Residential | Mark Harding | Failed | Monday, August 14, 2017 |

Corrective Action Required

| | | |
|---|------|--|
| 1 | Misc | 2220 - -NORTH GARAGE WALL PLATE BOLT -FIRESTOP BATH VENT BOX OUT IN GARAGE WALL. - FIRESTOP HEAT CHASE FROM JOIST SPACE 1ST FLOOR -2222- PLUMBING PROTECTION PALTES NOTCHED FLOOR JOSIT OVER KITCHEN -PLUMING PROTECTION PLATES 2ND FLOOR - STRAP CUT PLATES 2ND FLOOR AT 3" DWV. -2224 BLOCK OFF BSMT SOUTH EAST CORNER FROM 1ST FLOOR. 2226 NOTCHED FLOOR JOIST FOR AC LINE SOUTH SIDE. NOTCHEDN JOIST OVER KITCHEN CUT OFF UFER GROUND AND REBAR AND INSTLL IN THE BSMT. FIRESTOP INCOMPLETE. |
|---|------|--|

INSTALL PLUMBING PROTECTION PLATES ALL UNITS WHERE
REQUURED.

Comments: