

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171149, Building Permit - Commercial
Address: 1710 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Tuesday, August 15, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY **UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT SPACES 106 & 109 ONLY**

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

In-wall Inspection	John Borns	Partial	Tuesday, August 15, 2017
---------------------------	------------	---------	--------------------------

Partial Correction

1 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: EAST DEMISING WALL COMPLETE; N WALL OF 104; ALL WALLS EXCEPT WET WALLS AT REAR;

Partial Correction

2 Misc

DEMISING WALL AT EAST IS NO LONGER DESIGNATED AS FIRE-RATED AND CAN BE COVERED WHEN READY.

Comments: